NORTH CAROLINA BOARD OF EXAMINERS
FOR ENGINEERS AND SURVEYORS

POLICY

Title: **FIRE ALARM SYSTEM DESIGN**

Policy Number: BP-0709-1

Status: Draft_____ Date Originated: 5/18/2007 By: William H. Clark, Jr., PE
For Approval_____ Rev. No.: _____
Final XX Referred to Engineering Comm Date_____

Date for Board Approval: 9/13/2007 Date Adopted: 9/13/2007
Date to be Reviewed: 2013 Date Reviewed: 7/14/10

Category(s): Engineering, unlicensed practice, seal

Keywords: Fire Alarm system, shop drawings, Section 907 NC Fire Code

---

The preparation of fire alarm system shop drawings from sealed engineering design drawings does not constitute the practice of engineering as defined in G.S. 89C. This relates to the construction documents required in Section 907 of the 2006 North Carolina Fire Code. However, if held out as an engineering service or as being done by a PE then the work must be signed and sealed and the company must be appropriately licensed with this Board.