
**NORTH CAROLINA BOARD OF EXAMINERS
FOR ENGINEERS AND SURVEYORS**

Policy

Fire Alarm System Design			
NUMBER: BP-0709-1		REV. NO.: 1	ORIGINAL BOARD APPROVAL: 09/13/2007
			LATEST COMMITTEE REVIEW: 03/04/2020
CATEGORY(IES)	<input type="checkbox"/> Surveying	<input checked="" type="checkbox"/> Engineering	<input checked="" type="checkbox"/> Technical
	<input type="checkbox"/> Unlicensed	<input type="checkbox"/> Seal	
ORIGINATION:	<input type="checkbox"/> Surveying Committee	<input checked="" type="checkbox"/> Engineering Committee	<input type="checkbox"/> Other

The preparation of fire alarm system shop drawings from sealed engineering design drawings does not constitute the practice of engineering as defined in G.S. 89C. This relates to the construction documents required in ~~Section 907 of the 2006~~ the North Carolina Fire Code. However, if held out as an engineering service or as being done by a PE then the work must be signed and sealed and the company must be appropriately licensed with this Board.