



8. Pretreatment components that have not been evaluated and approved in NC by DENR pursuant to 15A NCAC 18A.1957 or .1969.
9. Requires pretreatment before disposal, other than by a conventional septic or other system approved under NCDENR Rules 15A NCAC 18A.1957 or .1969.
10. Requires use of sewage pumps prior to the septic tank or other pretreatment system, except for systems subject to the NC Plumbing Code or which consist of grinder pumps and associated pump basins that are approved and listed in accordance with standards adopted by the National Sanitation Foundation (NSF).
11. An individual system required by 15 A NCAC 19A.1952 to use more than one pump or siphon, with the same functionality, in a single pump tank. A PE would not be required when one pump is for the filter and a second pump is for dousing the field.
12. Includes a collection sewer, prior to the septic tank or other pretreatment system, which serves two or more buildings, except for systems subject to the NC Plumbing Code.
13. Includes structures which have not been pre-engineered.
14. Designed for the collection, treatment and disposal of industrial process wastewater.
15. Proposed to use pump models that are not listed by Underwriter Laboratories (UL) or an equivalent third party electrical testing and listing agency.